

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3265-0057:103 Page 1 of 1

**CATEGORY:** Power-Operated Doors

**LISTEE:** Stanley, Rt. 6 & Hyde Rd., Farmington CT 06032  
Contact: \*Dean Negrelli (860) 679-6453

**DESIGN:** Model DURA-GLIDE 5200 and 5300 exit doors. These units are available in single slide or bi-part. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 117 VAC, 60 Hz

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as non-rated sliding doors for use exit locations where fire-rated door is not required. For indoor use only. Authority having jurisdiction should be consulted prior to installation.

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager